

Our Ref: HL/M1203052
Test Report: MA4577/A section 1 & 2

6th November 2012

NTG Plastik Sanayi VE Ticaret A.S.
Kurtkoy Sanayi MH Ensar SK No. 18,
34906 Pendik,
Istanbul,
Turkey

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYETHYLENE – COMPONENTS

5240

NTG PE100 Fittings. Black coloured, injection moulded, HDPE 100 fittings. For use with water up to 60°C.

APPROVAL NUMBER: 1210533


APPROVAL HOLDER: NTG PLASTIK SANAYI VE TICARET A.S.

The Scheme reserves the right to review approval. This approval is valid between October 2012 and October 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme