



BULGARKONTROLA S.A.

**CARGO & DAMAGE SURVEYS, LABORATORY ANALYSES,
CONFORMITY ASSESSMENT & TECHNICAL INSPECTIONS,
MANAGEMENT SYSTEMS**



Head office: 23, Sitnyakovo Blvd., 1505 Sofia, Bulgaria
Emergency mobile: +359 889 400 400, Tel.: +359 2 989 4070, Fax: +359 2 988 2354
E-mail: sales@bulgarkontrola.bg, cert@bulgarkontrola.bg

CERTIFICATE OF CONFORMITY 14 - HCICOCSP-2127

In accordance with part III of Ordinance with the essential buildings' requirements and conformity assessment of construction products (State Gazette 106/2006) it has been stated that the **construction products**

FITTINGS MADE OF HIGH-DENSITY POLYETHYLENE PEHD 100, UNDER THE TRADE NAME „NTG”

are designed for construction of potable water supply systems outside buildings and branching to buildings, with product range, connection method, operating pressure and dimensions as per Supplement № 1 to this Certificate.

**PLACED ON THE MARKET BY
PANAYOT PEYCHEV Ltd
3 Odrin str., Burgas 8000
Id No 102986183**

**MANUFACTURED BY
NTG PLASTIK San.ve Ticaret. A.S.
Ensar Sk.No.30, TR-34906 Pendik-Istanbul, Turkey**

are manufactured under the conditions of introduced by the manufacturer system for production control and are submitted by the manufacturer to ongoing testing of test specimens in accordance with a prescribed test plan. The Conformity Assessment Directorate at Bulgarkontrola S.A. has performed initial type-testing, initial inspection of the production control and performs continuous surveillance, assessment and approval of the production control.

This Certificate attests that all provisions concerning the conformity assessment of the construction product and the requirements of

BDS EN 12201-3:2011+A1:2013


were applied and fulfilled and that the product conforms to all prescribed requirements.
са приложени и изпълнени и че продуктът съответства на всички предписани изисквания.

This certificate is rescind the certificate No 14-HCICOCSP-2000 on 04/11/2013 and remains valid as long as the conditions laid down in the technical specification are fulfilled and the production conditions or the production control are not modified significantly.

**Date 18/11/2014
Sofia**

**Director of "Conformity Assessment" Dept.:
/T. Lyubenova/**

BULGARKONTROLA S.A. – Sofia with identification number 14
Permit № ПОССП-14/24.01.2008 г., issued by MRRB






Supplement № 1
to Certificate of Conformity № 14 – НСИСОССП -2127

Product range	SDR	PN (bar)	Nominal dimensions d_n mm
1	2	3	4
Segmented fittings designed to be connected through polyfusion welding			
90° Elbow segmented	11	16	125 + 800
	17	10	20 + 1200
45° Elbow segmented	11	16	125 + 800
	17	10	125 + 1200
30° Elbow segmented	11	16	20 + 800
	17	10	20 + 1200
Elbow segmented 5°, 11°, 15°, 22°, 60°, 75°	11	16	20 + 800
	17	10	20 + 1200
Tee 90° segmented	11	16	125 + 1200
	17	10	125 + 800
Tee 45°, 60° segmented	11	16	90 + 630
	17	10	90 + 630
Reduced Tee 90° segmented	11	16	125 + 50 / 800 + 90
	17	10	125 + 90 / 1000 + 63
Reduced Tee 45°, 60° segmented	11	16	90 + 63 / 630 + 63
	17	10	90 + 63 / 630 + 63
Flange adaptor segmented	11	16	355 + 800
	17	10	355 + 800
Reducer segmented	11	16	140 + 90 / 800 + 710
	17	10	140 + 90 / 1200 + 800
Cross segmented	11	16	90 + 630
	17	10	90 + 1200
Adaptor	11	16	63 + 630
	17	10	63 + 1200
Injection Fittings designed to be connected through polyfusion welding			
90° Elbow Spigot, Injection	11	16	20 + 315
	17	10	63 + 315
45° Elbow Spigot, Injection	11	16	20 + 315
	17	10	63 + 315
30° Elbow Spigot, Injection	11	16	90 + 315
	17	10	90 + 315
Tee 90° Equal Spigot, Injection	11	16	20 + 315
	17	10	63 + 315

Date 18/11/2014
Sofia

Director of "Conformity Assessment" Dept.:

T. Lyubenova



BULGARKONTROLA S.A. – Sofia with identification number 14
Permit № ПОССП-14/24.01.2008 г., issued by MRRB




1	2	3	4
Reduced Tee 90°, Injection	11	16	40 ÷ 25 / 315 ÷ 110
	17	10	75 ÷ 63 / 315 ÷ 110
Reduced Tee 45°, Injection	11	16	63 ÷ 110
	17	10	63 ÷ 110
Flange Adaptor Spigot, Injection	11	16	20 ÷ 710
	17	10	63 ÷ 1000
Flange Adaptor short, Injection	11	16	200 ÷ 710
	17	10	200 ÷ 1000
End Cap Spigot, Injection	11	16	20 ÷ 800
	17	10	20 ÷ 900
Reducer Spigot, Injection	11	16	25 ÷ 20 / 315 ÷ 225
	17	10	75 ÷ 63 / 315 ÷ 225
Reduced Spigot, Injection	11	16	160 ÷ 225 / 450 ÷ 630
	17	10	160 ÷ 225 / 450 ÷ 900
Flange with PP covering	11	16	20 ÷ 400
	17	10	200 ÷ 630
Flange with PP covering ANSI 150 lb			20 ÷ 400
Elektrofusion fittings			
Tapping Saddle	11	16	40 ÷ 20 / 630 ÷ 160
Tapping Valve	11	16	40 ÷ 20 / 315 ÷ 63
Socket	11	16	20 ÷ 630
Reduced socked	11	16	25 ÷ 20 / 225 ÷ 160
Tee	11	16	20 ÷ 630
Reduced Tee	11	16	32 ÷ 20 / 315 ÷ 200
90° Elbow	11	16	20 ÷ 315
45° Elbow	11	16	32 ÷ 315
30° Elbow	11	16	32 ÷ 315
Threaded fittings			
Brass female transition	11	16	20 x 1/2" ÷ 125 x 4"
Brass mail transition	11	16	20 x 1/2" ÷ 125 x 4"
Steel female transition	11	16	20 x 1/2" ÷ 315 x 12"
PEHD mail transition	11	16	20 x 1/2" ÷ 63 x 2"
Brass female transition	11	16	20 x 1/2" ÷ 63 x 2"

Date 18/11/2014
Sofia

Director of "Conformity Assessment" Dept.:

/T. Lyubenova/



BULGARKONTROLA S.A. – Sofia with identification number 14
Permit № ПОССП-14/24.01.2008 г., issued by MRRB